

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE <b>1</b>	OF PAGES <b>3</b>
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">A004</div>		3. EFFECTIVE DATE <div style="text-align: center;">07/20/12</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">AC-12-03931</div>		5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY FAA, MIKE MONRONEY AERONAUTICAL CENTER NAS CONTRACTING TEAM AMQ-210 P O BOX 25082 OKLAHOMA CITY OK 73125-4929				7. ADMINISTERED BY <i>(If other than Item 6)</i> <b>FOR MORE INFORMATION CONTACT:</b> Name: Lori Lemons Telephone No. (405) 954-5487		
8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>  All Offerors				<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO.  DTFAAC-12-R-03931	
					9B. DATED <i>(SEE ITEM 11)</i>  05/23/12	
				<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
*TO BE COMPLETED BY VENDOR IF NOT COMPLETE CODE _____ FACILITY CODE _____					10B. DATED <i>(SEE ITEM 13)</i>	
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is <input type="checkbox"/> extended <input checked="" type="checkbox"/> is not extended. <b>NOTE: If offers are hand carried, additional time should be allowed to access the depository facility due to heightened security requirements.</b> Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Item 8 and 15, and returning <u>1</u> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA <i>(If required)</i>						
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>						
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.					
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation data, etc.)</i> SET FORTH IN ITEM 14,					
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/>	D. OTHER <i>(Specify type of modification and authority)</i>					
E. <b>IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> <b>is required to sign this document and return 1 copies to the issuing office.</b>						
14. DESCRIPTION OF AMENDMENT/MODIFICATION <i>(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</i>						
The Request for Offer referenced in Item 9A above for replacement of ILS for runway at Houma-Terrebonne Airport is amended as follows: <ol style="list-style-type: none"> <li>1. Page 26R of the SIR/RFO is replaced by Page 26R(a) to add Addendum Two as Attachment 7.</li> <li>2. Section J as included in Amendment A003 is rescinded in its entirety and replaced (attached).</li> <li>3. The time and date for receipt of proposals remains the same.</li> </ol> Reference Item 11 above. Acknowledge receipt of this amendment to: FAA Bid & Proposal Officer (AMQ-100) Room 313, Multi-Purpose Building 6500 South MacArthur Boulevard (P.O. Box 25082, Zip 73125-4933) Oklahoma City, OK 73169-4933						
15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>				16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
BY _____ <i>(Signature of person authorized to sign)</i>				BY _____ <i>(Signature of Contracting Officer)</i>		

**PART III - SECTION J**  
**LIST OF ATTACHMENTS**

<u>ATTACHMENT</u>	<u>TITLE</u>	<u>DATE</u>	<u>NO. OF PAGES</u>
1	Specifications	N/A	173
	Attachment 1-1 Government Furnished Property	N/A	1
	Attachment 1-2 Drawings	Various	48
	Attachment 1-3 FAA Advisory Circular No. 150/5370-2 F	9/29/11	58
	Attachment 1-4 FAA-C-1217f	2/26/96	40
	Attachment 1-5 FAA-STD-019e	12/22/05	112
	Attachment 1-6 FAA-C-1391c	12/01/09	36
2	Davis Bacon Wage Rate Decision General Decision No. LA120004 Construction Type: Building	4/13/12	6
3	Standard Form 25, Performance Bond	5/96	2
4	Standard Form 25A, Payment Bond	10/98	2
5	Contractor's Release	5/05	1
6	Addendum One	07/18/12	5
7	Addendum Two	07/20/12	2

**DATE:** July 20, 2012

**SUBJECT:** Addendum No. One to the Specifications and Drawings for replacement of Instrument Landing System (ILS) for runway 13R at Houma-Terrebonne Airport in Houma, LA.

This Addendum modifies and takes precedence over the original Specifications and Drawings and forms a part of the contract documents.

**Clarification to Question and Answer #15 on Addendum #1.**

**15. LOC S001 – Detail 3 indicates concrete steps & detail 8 indicates fiberglass steps. Please clarify.**

Please use the following specs for the steps and its landing, steel construction (Drawing HUM-D-LOC18-S001 note #8).

- 1) Both steps and landing confirm to OSHA.
- 2) Overall height from the top of the landing is 49".
- 3) The landing is straight thru.
- 4) The finishing is duplex system with any available color.
- 5) Use FS Industries- PO Box 72659, 50 Sprague Street, Providence, RI 02907. Toll free: 1-800-421-0314 In RI: 401-421-0314 , Fax: 401-421-5679, [www.fsindustries.com](http://www.fsindustries.com). (See attached FS Industries typical stair and landing sheet).




STEEL CHANNEL MEZZANINE  
TYPICAL STAIR & LANDING

Customer: \_\_\_\_\_

Job number: \_\_\_\_\_

SL120  
Rev. 7/15/09



FS INDUSTRIES P.O. BOX 72659 PROVIDENCE, RI 02907 (401) 272-4570 WWW.FSINDUSTRIES.COM

